

## Planning Kent

---

**To:** KENT PLANNING BOARD 2018; KENT PLANNING BOARD CONSULTANTS 2018  
**Cc:** Joel Greenberg  
**Subject:** Highway Itr regarding Rienzi Project

FYI.

Vera Patterson  
Kent Planning Board  
25 Sybil's Crossing  
Kent, NY 10512  
845-225-7802 (T)  
845-306-5283 (F)  
[planningkent@townofkentny.gov](mailto:planningkent@townofkentny.gov)

---

**From:** Rich Othmer  
**Sent:** Thursday, October 04, 2018 10:39 AM  
**To:** Planning Kent  
**Subject:** FW:

---

**From:** Rich Othmer  
**Sent:** Thursday, October 04, 2018 10:39 AM  
**To:** 'Paul E Denbaum'; 'jmangarillo@rsaengrs.com'; Building Inspector  
**Cc:** 'Joel Greenberg'  
**Subject:**

To All;

In the matter of the proposed residence for Mr. Paul Rienzi on Kentview Drive in Kent I require the following;

Install ADS plastic pipe (12" or 15" to match existing) the whole length of the road frontage from house # 59 -- house # 67 & backfill with clean soil, seed & hay. Additionally, about 2/3 of the way down; install a catch basin & connect to existing pipe crossing the road & connect to the lower grade pipe on the same side of the road so that this water is directed to the new basin.

Any piped drainage from the house is to be connected to the new basin to prevent water from flowing over the road & creating ice dams.

Thanks;

Rich Othmer

Highway Super Duper